

Operations Division
Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

August 31, 2021

Dear **Morrison Elementary School** Community,

As a part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, **24** water outlets at your school were initially tested for lead on **May 28, 2021**. Of those outlets, **22** outlets produced water that was below the action level of 10 ppb. **Two (2)** water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off.

Below outlines the confirmed corrective action steps that were taken for those **Two (2)** water outlets that tested above the action limit.

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Confirmed Corrective Action Description
05/28/2021	2	1	WF	Next to 204	59.43	NA	1	Replaced with Hydration Station ¹
8/10/2021	2	1	WF	Next to 204	<1	NA	1	Remediation Complete
05/28/2021	1	9	FT	In Rm 108 left	13.54	NA	1	Replaced faucet and any accessible lines, elbows back to the shutoff valve and retested.
8/10/2021	1	9	FT	In Rm 108 left	3.2	NA	1	Remediation Complete

Notes:

AA = Above Action limit of 10 ppb
BA = Below Action limit of 10 ppb
MDL = Method Detection Limit
PQL = Practical Quantitation Limit
J = Result estimated below the PQL
< = not detected above PQL
ppb = parts per billion
NA = Not Available

Outlet Types:

WF = Water Fountain/Bubbler
HS = Hydration Station/Bottle Filling Station
FT = Faucet/Tap
FP = Food Prep/Pot-Filler/Kitchen Kettle
IM = Ice-Maker

¹Hydration Station has passed subsequent testing and is turned on for use. Hydration Stations offer filtered water and bottle filling stations that remove, on average, 99.3 percent of lead from drinking water. These filtered water bottle filling stations are more effective, efficient, and affordable than the alternatives to lead remediation.



THE SCHOOL DISTRICT OF
PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at:

www.philasd.org/waterresults.

Sincerely,

A handwritten signature in blue ink that reads "Steve Link". The signature is fluid and cursive, with the first name "Steve" and last name "Link" clearly distinguishable.

Steve Link
Environmental Director