



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services

440 North Broad Street

Philadelphia, Pennsylvania 19130

215-400-4750

November 29, 2021

Dear **Stanton Elementary** School Community,

As a part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, **Nine (9)** water outlets at your school were initially tested for lead on **October 07, 2021**. Of those outlets, **Nine (9)** outlets produced water that was below the action level of 10 ppb. During the initial sampling event **Two (2)** water outlets were not available for testing. These outlets were sampled on **October 20, 2021**.

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	PQL (ppb)	Confirmed Corrective Action Description
10/20/2021	2	9	FT	Teacher's Lounge	2.3	1	No Action Required
10/20/2021	3	11	HS	Outside RM 303	<1	1	No Action Required

Notes:

AA = Above Action limit of 10 ppb

BA = Below Action limit of 10 ppb

MDL = Method Detection Limit

PQL = Practical Quantitation Limit

J = Result estimated below the PQL

< = not detected above PQL

ppb = parts per billion

Outlet Types:

WF = Water Fountain/Bubbler

HS = Hydration Station/Bottle Filling Station

FT = Faucet/Tap

FP = Food Prep/Pot-Filler/Kitchen Kettle

IM = Ice-Maker

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at:

www.philasd.org/waterresults.

Sincerely,

Steve Link

Environmental Director