



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

July 19, 2022

Dear **Nebinger Elementary School** Community,

As part of the School District of Philadelphia's effort to provide students and staff with safe, accessible, and appealing drinking water, your school's water was tested for lead on **July 06, 2022**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

There were **12** drinking water outlets tested at your school. Of those outlets, **12** outlets produced water that was below the action level of 10 ppb. **No** water outlets were found to have results above the water safety threshold.

An action plan is being developed to determine the best way to address the outlet(s) that was shut-off (if applicable to your school), including replacing the outlet with a new hydration station or, if the outlet is not needed because another outlet is available nearby, the outlet may be permanently removed from the school. Once a decision is made, the Maintenance Department will perform the new installation or remove the existing outlet.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: www.philasd.org/waterresults.

Sincerely,

Steve Link
Environmental Director



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	PQL	Action Limits
07/06/2022	00	04	FP	Double food prep sink in kitchen (left side)	4.9	1	BA
07/06/2022	00	04	FP	Double food prep sink in kitchen (right)	3	1	BA
07/06/2022	00	06	HS	Outside girls bathroom	<1	1	BA
07/06/2022	00	10	HS	In hall by art room	<1	1	BA
07/06/2022	01	14	HS	Outside room 106	<1	1	BA
07/06/2022	01	33	HS	In hall by elevator	<1	1	BA
07/06/2022	02	34	HS	Left of room 201	<1	1	BA
07/06/2022	02	42	HS	Left of room 207	<1	1	BA
07/06/2022	03	44	HS	Next to room 302	<1	1	BA
07/06/2022	03	49	HS	Left of room 307	<1	1	BA
07/06/2022	04	50	HS	Next to room 407	<1	1	BA
07/06/2022	04	56	HS	Right of room 402	<1	1	BA

Notes:

AA = Above Action limit of 10 ppb

BA = Below Action limit of 10 ppb

MDL = Method Detection Limit

PQL = Practical Quantitation Limit

J = Result estimated below the PQL

< = not detected above PQL

ppb = parts per billion

Outlet Types:

WF = Water Fountain/Bubbler

HS = Hydration Station/Bottle Filling Station

FT = Faucet/Tap

FP = Food Prep/Pot-Filler/Kitchen Kettle

IM = Ice-Maker