



THE SCHOOL DISTRICT OF
PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

December 16, 2022

Dear **Lincoln High School** Community,

As part of the School District of Philadelphia's effort to provide students and staff with safe, accessible, and appealing drinking water, your school's water was tested for lead on **December 06, 2022**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

There were **25** outlets tested at your school. Of those outlets, **25** outlets produced water that was below the action level of 10 ppb. **No** water outlets were found to have results above the water safety threshold.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: www.philasd.org/waterresults.

Sincerely,

Steve Link
Environmental Director



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	PQL	Action Limits
12/06/2022	01	01	HS	Outside cafeteria right side	<1	1	BA
12/06/2022	01	02	HS	Outside cafeteria left side	<1	1	BA
12/06/2022	01	03	HS	Outside cafeteria main entrance	<1	1	BA
12/06/2022	01	04	HS	Main entrance across from police office	<1	1	BA
12/06/2022	01	05	HS	Next to room 102	<1	1	BA
12/06/2022	01	06	HS	Across from room 106&108	<1	1	BA
12/06/2022	01	07	HS	Across from room 118	<1	1	BA
12/06/2022	01	13	HS	Right side of room 165	<1	1	BA
12/06/2022	01	14	HS	170 hall between staff bathroom	<1	1	BA
12/06/2022	01	15	HS	Next to 192B	<1	1	BA
12/06/2022	01	16	HS	Left side freshman entrance	<1	1	BA
12/06/2022	01	17	HS	Outside main gym	<1	1	BA
12/06/2022	01	18	HS	In main gym	<1	1	BA
12/06/2022	01	19	HS	In small gym	<1	1	BA
12/06/2022	01	20	HS	Day care	<1	1	BA
12/06/2022	01	21	HS	Pool	<1	1	BA
12/06/2022	01	22	HS	FH football locker room	<1	1	BA
12/06/2022	01	23	HS	FH visitors locker room	<1	1	BA
12/06/2022	01	24	HS	FH baseball locker room	<1	1	BA
12/06/2022	01	25	HS	FH soccer locker room	<1	1	BA
12/06/2022	02	08	HS	Across from room 229A	<1	1	BA
12/06/2022	02	09	HS	Across from room 220	<1	1	BA
12/06/2022	02	10	HS	Across from room 210	<1	1	BA
12/06/2022	02	11	HS	Across from room 203	<1	1	BA
12/06/2022	02	12	HS	Outside stairway 3	<1	1	BA

Notes:

AA = Above Action limit of 10 ppb
BA = Below Action limit of 10 ppb
MDL = Method Detection Limit
PQL = Practical Quantitation Limit
J = Result estimated below the PQL
< = not detected above PQL

Outlet Types:

WF = Water Fountain/Bubbler
HS = Hydration Station/Bottle Filling Station
FT = Faucet/Tap
FP = Food Prep/Pot-Filler/Kitchen Kettle
IM = Ice-Maker



THE SCHOOL DISTRICT OF
PHILADELPHIA

Operations Division

Office of Environmental Management and Services

440 North Broad Street

Philadelphia, Pennsylvania 19130

215-400-4750

ppb = parts per billion