



## SUMMARY OF PAINT & PLASTER STABILIZATION ACTIVITIES ENVIRONMENTAL SITE ASSESSMENT

for  
John B. Kelly School #6470  
5116 Pulaski Avenue, Philadelphia, PA 19144

Prepared For:  
Mr. Eddie Escobio  
Operations Project Manager  
School District of Philadelphia  
Office of Environmental Management & Services 440 North Broad Street  
3rd Floor – Portal C Philadelphia, PA 19130

Submitted by:  
BATTa ENVIRONMENTAL ASSOCIATES, INC.  
Delaware Industrial Park  
6 Garfield Way  
Newark, Delaware 19713-5817

November 18, 2020

Project Number: 543520F  
Date of Project: June 1, 2020 through October 17, 2020

Prepared By:

A handwritten signature in black ink that reads "Eric Stone".

Eric Stone,  
Project Manager / Geologist

Reviewed By:

A handwritten signature in black ink that reads "Steven C. Woronicak".

Steven C. Woronicak  
Operations Manager



November 17, 2020

Mr. Eddie Escobio  
Operations Project Manager  
School District of Philadelphia  
Office of Environmental Management & Services  
440 North Broad Street  
3rd Floor – Portal C Philadelphia, PA 19130

Reference: Lead Safe Certification Letter - John B. Kelly School #6470

Dear Mr. Escobio,

Batta Environmental Associates, Inc. provided Lead Stabilization Oversight at the Ellwood School, School #6470, located at 5116 Pulaski Avenue, Philadelphia, PA 19144. The stabilization scope of work was developed based on the Lead Safe Certification Assessment of the damaged paint observed and confirmed as lead-based paint by XRF analysis. The assessment scope was limited to the interior, below the suspended ceiling/enclosed ceiling, and student/teacher occupied areas only.

Mr. Emlyn Drake, a certified RRP Lead Dust Sampling Technician performed the oversight activities during the stabilization throughout the summer and fall of 2020. This letter certifies that the John B. Kelly School is deemed "Lead Safe" and is valid only up to the day of the stabilization activities.

Please contact me if you have any questions at (302) 737-3376, extension 106.

Sincerely,

A handwritten signature in black ink, reading "Stephen C. Woronicak".

Stephen C. Woronicak  
Operations Manager  
Batta Environmental Associates, Inc.

Attachments include:

Final Report - Summary of Paint & Plaster Stabilization Activities  
Appendix A. Scope of Work Table  
Appendix B. EPA Checklist Table  
Appendix C. Oversight Table  
Appendix D. Sample Results Table  
Appendix E. Environmental Firm Certification Documentation of Training  
Appendix F. Paint Contractor Certifications or Documentation of Training



## TABLE OF CONTENTS

- I. Introduction
- II. Methods Executive Summary
  - A. Preliminary Steps
    - i. Parent and Staff Notifications
    - ii. Decluttering
    - iii. Wall Hangings
    - iv. Swing Space
    - v. Facilities Building Cleaning Staff Training
  - B. Pre-Cleaning
  - C. Paint & Plaster Stabilization Procedures
    - i. Work Practices
    - ii. Oversight
  - D. Cleanup & Completion
    - i. Cleanup
    - ii. Testing
- III. Oversight
  - A. Scope of Work
  - B. EPA Checklist
  - C. Oversight
  - D. Sample Results

Appendix A. Scope of Work Table

Appendix B. EPA Checklist Table

Appendix C. Oversight Table

Appendix D. Sample Results Table

Appendix E. Environmental Firm Certification Documentation of Training

Appendix F. Paint Contractor Certifications or Documentation of Training



## I. INTRODUCTION

Batta Environmental Associates, Inc. (Batta), was requested by the School District of Philadelphia's Office of Environmental Management Services (OEMS) to perform oversight and clearance testing during a paint and plaster stabilization project being performed by the School District Painters at John B. Kelly School #6470, located at 5116 Pulaski Avenue, Philadelphia, PA 19144. The purpose of the oversight was to document that all parts of the US Environmental Protection Agency (EPA) Lead Renovation, Repair and Painting rules were being followed and documented.

## II. METHODS EXECUTIVE SUMMARY

### A. Preliminary Steps

#### i. Parent and Staff Notifications

Parents and staff were notified of the paint and plaster project by mail several weeks prior to the commencement of the project. Additionally, prior to the start of the project, parent and staff meetings were held by OEMS, Maintenance, and Operations to explain the process of the paint and plaster projects and to field any questions or concerns.

#### ii. Decluttering

Classrooms, closets and other storage areas were decluttered prior to the commencement of stabilization work. Coordination of the decluttering activities was made between teachers and facilities staff to ensure that outdated and unneeded academic materials were discarded, and that resources were provided to assist in the decluttering tasks such as support staff for heavy lifting and/or moving large furniture and additional recycling dumpsters.

#### iii. Wall Hangings

Posters, bulletin boards, framed art and other wall hangings were removed prior to the commencement of the paint stabilization project. This was coordinated with teachers by the Operations Division at the kick-off meeting, and during the phasing of the project, with the help of the Principal.

#### iv. Swing Space

Swing space was identified prior to the commencement of stabilization work to ensure that classrooms were available during the school year. A plan was created on a school-by-school basis to relocate students and teachers from classrooms during the course of this work. All work areas were scheduled for cleaning by facilities staff after the paint stabilization work was completed by Maintenance Painting Staff.

v. Facilities Building Cleaning Staff Training

Facilities Building Cleaning Staff were provided with information about this project and expectations for post-cleaning, including use of wet-wipes and HEPA vacuums.

B. Pre-Cleaning

On an as-needed basis, for areas such as cluttered storage closets, that required extensive movement of materials, HEPA vacuuming, and wet-wiping prior to paint and plaster stabilization, the Maintenance Environmental staff performed a pre-cleaning in advance of stabilization work. The intent of this task was to provide a clean work area prior to decluttering and stabilization.

Additionally, post-cleaning was conducted by facilities staff after paint and plaster stabilization was completed. This included the HEPA vacuuming and wet-wiping of all horizontal surfaces and polishing floors.

C. Paint & Plaster Stabilization Procedures

Paint and plaster stabilization work complied with the EPA's Lead RRP rule. All staff conducting this work were trained and/or certified as Lead RRP workers.

The following procedures were followed:

i. Work Practices

- Isolate work areas to restrict dust from impacting adjacent areas.
- Post signs/notifications as per EPA Lead RRP.
- Place "walk-off" pads at all access points into/out of work area.
- Seal all openings [windows, doors, and HVAC system registers/grilles] inside work areas as per direction from on-site environmental monitors and consistent with the EPA Lead RRP rules & guidelines.
- Workers are to wear disposable clothing and foot coverings while inside work areas and will not leave work areas wearing disposable clothing.
- Move/cover all remaining objects in work area to protect them. Including all open bins, shelves and boxes in the classroom.
- Employ/Erect "portable" dust containment barrier systems to limit the size of work areas requiring post-cleaning and limit testing and exposure.
- Place plastic floor coverings to extend at least 6 feet out from vertical surfaces being stabilized unless utilizing vertical barriers/containment systems.
- Perform all paint stabilization work in compliance with the EPA Lead RRP rules & guidelines and as per the directions of on-site environmental monitors to minimize dust contamination.
- Take all steps necessary to ensure that no dust or debris leaves the work area while the work is being performed.

- Use precautions to ensure that all employees, tools, and other items, including the exteriors of waste containers, are free of dust and debris before leaving the work area.
- Collect all paint chips & debris, fold up plastic floor coverings and any other plastic sheeting used on horizontal surfaces, without dispersing dust or debris and dispose of the material in heavy duty plastic waste bags.
- Do not use power tools.
- Do not use dry sweeping with brooms.
- Do use water/misting during stabilization to minimize dust.
- Do use HEPA vacuums and wet wiping/cleaning techniques.

ii. Oversight

The environmental technician will oversee paint and plaster stabilization work to ensure compliance with lead safe work practices. An oversight report will be completed at the end of every shift to record the work areas that were stabilized. The following tasks will be verified and recorded:

- Pre-cleaning
- Contents moved
- Work area prepped
- Surfaces stabilized
- Contents back in place
- Final inspection approval and photos

D. Cleanup & Completion

The following clean-up and completion procedures were performed for each work area following the completion of stabilization work:

i. Cleanup

- There should be no signs of loose, peeling, flaking, bubbling or crumbling paint or plaster visible on walls or ceilings or on any other painted surfaces.
- There should be no visible signs of paint chips, debris or dust of any kind on surfaces within "contained" and isolated work areas NOR outside of the contained and isolated work areas.
- Window sills, floors, baseboards, shelving units, tops of cabinets, desks, chairs, tables and all other horizontal surfaces must be free of any visible signs of paint and plaster dust and/or debris.
- There must be absolutely no visible signs of paint chips, and/or paint/plaster dust or debris on academic/educational materials, including books, bins, toys, desks, chairs, carpets, papers, etc., after each work shift and to allow for re-occupancy the next day,

- Any remaining paint and plaster must be tightly adhered to wall and ceiling surfaces such that it cannot be further damaged, pried off or disturbed by “simple fingernail pressure” otherwise work will not be considered to be successfully completed.
- Newly painted surfaces should match the aesthetics of the area in total and should cover the entirety of the wall or ceiling area that was addressed through this work. No visible “patches” of paint should be observed.

ii. Testing

The District and the PFT’s Environmental Consultant worked closely to develop an agreed upon approach to verify that stabilization work was performed in accordance with lead safe work practices, and that classrooms would be safe for re-occupancy by children and staff. This approach exceeds the EPA Lead RRP rule requirements in terms of the types of, and amounts of, testing performed. Testing will take place in work areas. The areas will be cleaned by general cleaners after the stabilization work is completed and the clearance testing is performed.

Qualitative testing methods, i.e., EPA RRP verification wipe testing and colorimetric wipe testing, will be compared with the quantitative testing method of Atomic Absorption Spectrophotometry (AAS) as indicated in the testing protocol below. If the comparison testing is consistently correlated, only qualitative testing will continue for the duration of the project.

a. Testing Protocol

Step 1 -- EPA RRP Verification Wipes and Colorimetric Wipes

The environmental consultant and painter foreman will coordinate the EPA RRP Verification Test Wipe in rooms/areas that have been stabilized and cleaned, and where plastic work area coverings have been removed and visual inspection conducted. After EPA RRP verification wipes pass the cleanliness standard for any surface and/or a 40 square feet (SF) section, the colorimetric testing will be conducted by the environmental consultant.

The colorimetric wipe tests will occur in “child-occupied areas” on approximately 10% of surfaces considered “clean” following the use of the verification wipes. These surfaces may include floors, window sills, or the tops of any other immovable objects that were covered and cleaned in each work area (e.g. CUVs, immovable bookshelves). Additional colorimetric wipes may be collected on surfaces that had been moved and covered and placed outside of the work area. These surfaces may include desks, chairs, bookshelves, etc.

“Child-occupied areas” will include: classrooms, restrooms, cafeterias, gymnasiums, and auditoriums that are routinely used by children in PK-1st

grade classrooms. Common areas that children in PK-1st grade classrooms only pass through, such as hallways, stairways, and garages are not included. "Child-occupied areas" will be identified by the Principal of each school.

#### Step 2 -- Response to Failed Tests

If colorimetric testing "fails," then the 40 SF area will be re-wiped by EPA RRP Wipes. The process will continue until both testing methods confirm a "pass."

#### Step 3 -- Flame Atomic Absorption Spectrophotometry (FAAS)

Flame Atomic Absorption Spectrophotometry (FAAS) will be used to verify and confirm the results of the colorimetric testing. FAAS will be used as a quality assurance/quality control for the colorimetric samples. Approximately 10% of the colorimetric samples should be submitted for FAAS analysis.

#### Step 4 -- Release Spaces Back to School/Operations

If EPA RRP wipes and colorimetric wipes are both acceptable, as determined on site, and if work was completed in accordance with this procedure, the room will be turned over to the District's Operations team for "deep cleaning" and for re- occupancy.

#### Step 5 — Ongoing Review

All sampling and testing data, information and results will be readily available and accessible for review by school staff, parents and members of the Oversight Advisory Committee and will be reviewed on a regular basis. Any suggested modifications, changes or other revisions will be considered by the School District of Philadelphia.

The three testing methods were conducted as follows:



Type of Clearance Tests	Building Component	Number of Sample Locations within Work	Type of Testing	Testing Specifications/ Limitations
EPA RRP Cleaning Verification Wipe	Floors, Countertops, Desks, Tables, Window Sills	One (1) wipe every 40 square or entire surface of component if surface area is less than 40ft <sup>2</sup> One (1) wipe for every window sill	Qualitative	<ul style="list-style-type: none"> <li>• Qualitative testing based on (white glove test)</li> <li>• According to RRP, the areas pass after the 3rd cleaning, regardless of Verification</li> </ul>
Colorimetric Wipe SKC, Inc. Full Disclosure® Instant Wipes	Floors, Countertops, Desks, Tables, Window Sills, Etc.	10% of surfaces considered “clean” following the use of EPA RRP Cleaning Verification Wipes	Qualitative	<ul style="list-style-type: none"> <li>• Qualitative testing based on colorimetric visual comparison</li> <li>• Lower Limit of Visual Detection is 18µg of lead</li> <li>• False positive and false negative interferences from silver, cadmium, barium, mercury, and titanium (percentages unknown)</li> <li>• Involves field preparation of sampling media using Reagents</li> </ul>
Flame Atomic Absorption Spectrophotometry (AAS)	Analyze Colorimetric Wipes from locations listed above	A minimum of one and a maximum of 10% of wipes will also be subjected to laboratory analysis by FAAS for verification. This testing method will be used on a periodic basis to validate the the accuracy of qualitative methods above.	Quantitative	<ul style="list-style-type: none"> <li>• Interior Floors and Desks: &lt; 20 µg/ft<sup>2</sup> This is based upon a District and PFT agreement. This is half the current HUD and EPA standard. This is tied to the detection level for the colorimetric wipe which is 18µg per wipe.</li> <li>• Window Sills: &lt; 100 µg/ft<sup>2</sup> D</li> </ul>

### III. OVERSIGHT

#### A. Scope of Work

A scope of work was developed for John B. Kelly School following a room-by-room inspection of Teacher/Student occupied areas of the school. During the inspection, the location and quantity of damaged paint and plaster, along with any associated debris and whether the damage was the result of an on-going moisture intrusion, were noted. This information was entered into a scope of work spreadsheet, which was provided to the School District Painting Department in order to create a schedule for the work to be completed.

During the paint and plaster stabilization project, additional areas of damage were found behind wall hangings, inside of closets that had now been decluttered, and behind furniture once it had been moved. These additional areas of work were added to the scope of work as they were observed.

The scope of work for John B. Kelly School is included in the Appendix A of this report.

#### B. EPA Checklist

Throughout the paint and plaster stabilization project, Criterion's on-site inspector observed, documented, and signed-off on tasks required by the EPA RRP. Additional notes were added to the EPA Checklist to document different oversight tasks that took place. These included documenting that warning signs were posted at the entrance to the work area, that the work area had been contained to prevent the spread of dust and debris, that all objects in the work area had been removed or covered, that all HVAC ducts in the work area were closed and covered, that windows in the work area were closed, that doors in the work area were closed and sealed, that doors that must be used in the work area were covered to allow passage but prevent the spread of dust, that floors in the work area were covered with taped-down plastic, that waste was being contained while on-site and while being transported, that the work site was properly cleaned after the renovations, that all paint chips and debris were picked up and that the protective sheeting was misted, folded dirty-side inward, and taped for removal, that the work area surfaces and objects were cleaned using HEPA vacuums and/or wet-wiping or mopping, that a certified renovator performed the post-renovation cleaning verification, a description of the post-renovation cleaning verification, including the number of wet and dry cloths used, and if the dust clearance testing was performed.

The EPA Checklist for John B. Kelly School is included in the Appendix B of this report.

#### C. Oversight

Throughout the paint and plaster stabilization project, Criterion's on-site inspector documented the day-to-day tasks performed for each work area. These tasks included the dates of pre-cleaning, the moving of the contents of the room, the prepping of the work area, the stabilization of the painted surfaces, and the final inspection.



The Oversight Table for John B. Kelly School is included in the Appendix C of this report.

#### D. Sample Results

Throughout the paint and plaster stabilization project, Criterion's on-site inspector documented all sampling results for each work area location. This included all RRP verification wipes, colorimetric wipes, and wipes to be submitted for Flame AAS analysis. Wipe result below 10 microgram per square ft (ft<sup>2</sup>) for lead is a passing result.

The Sample Results Table for John B. Kelly School is included in the Appendix D of this report.



## Appendix A. Scope of Work Table



## **Appendix B: John Welsh ES - EPA Checklist**



## Appendix C. Oversight Table



## Appendix D: Sample Results



## **Appendix E. Environmental Firm Certification Documentation of Training**





## **Appendix F. Paint Contractor Certifications or Documentation of Training**



			Lead Safe Certification															
			Name of Inspector: Charles Rhodes							Inspection Dates: 2/26/20 - 2/27/20								
			Inspection Company: Batta Environmental						ULCS#									
ULCS#	E	Space Type	On-Site Room Name	Student	Primary	Substrate	Color	Descriptio	Primary	XRF Reading	Primary	Additional Component	Substrate	Color	Description of	Additional	XRF Reading	Additional Component XRF
6470			Former Girl's Locker Room	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	6	0.3	N/A
6470			Former Girl's Locker Room Area outside	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470	1	Computer - Primary	Former Girl's Locker Room Restroom	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470	1		Former Girl's Locker Room Showers	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Mechanical Room adjacent to Stairwell to	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470	1	Primary	Gym	yes	W1	Concrete	Tan	Chipping	10	0.1	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A
6470	1	Primary	Gym	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	12	0.1	N/A
6470			Gym	yes	W2	Concrete	Tan	Chipping	8	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Gym	yes	W3	Concrete	Tan	Effloresce	12	0	N/A	Door Frame	Metal	Brown	Chipping	12	0	N/A
6470			Gym	yes	W4	Concrete	Tan	Chipping	6	0.1	N/A	Ait Vent	Metal	Blue	Chipping	10	0	N/A
6470			Gym Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	45	0.3	N/A
6470			Gym Office	yes	Ceiling	Plaster	White	Effloresce	24	0.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Gym Office Restroom	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	8	0.1	N/A
6470			Gym Office Restroom	yes	Floor	Concrete	Red	Chipping	10	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Gym Equipment Room	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Mechanical Room in Hallway to Gym	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Former Boy's Locker Room Entrance From	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Former Boy's Locker Room Restroom	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Former Boy's Locker Room Shower	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Storage Room behind Teacher's Dining	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Teacher's Dining Room	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	9	0.2	N/A
6470			Kitchen Dry Storage Room	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Red	Chipping	5	0.2	N/A
6470			Kitchen Office	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Red	Chipping	6	0.1	N/A
6470			Kitchen	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	8	0.1	N/A
6470			Kitchen Restroom	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Red	Chipping	8	0.3	N/A
6470			Kitchen Refrigerator Room	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Custodial Closet by Kitchen	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Red	Chipping	6	-0.3	N/A
6470			Cafeteria	yes	Center	N/A	N/A	N/A	N/A	N/A	N/A	Columns	Plaster	Blue	Chipping	30	-0.3	N/A
6470			Cafeteria	yes	W1	Concrete	Blue	Chipping	15	-0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Former Music Ensemble Room	yes	W1	Concrete	Green	Chipping	4	0.1	N/A	Door Frame	Metal	Green	21	0.3	N/A	N/A
6470			ISS Room	yes	W1	Concrete	Green	Chipping	5	0.1	N/A	Door Frame	Metal	Green	7	0.1	N/A	N/A
6470			ISS Room	yes	W4	Concrete	Green	Chipping	12	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Occupational and PT Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	18	0	N/A	N/A
6470			Occupational and PT Office	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Window frame	Metal	Green	6	0	N/A	N/A
6470			Special Education Liason Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	14	0.2	N/A	N/A
6470			Special Education Liason Office	yes	W3	Concrete	Green	Chipping	5	0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Auditorium	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Columns	Concrete	White	Chipping	6	0.1	N/A
6470			Auditorium	yes	W4	N/A	N/A	N/A	N/A	N/A	N/A	Columns	Concrete	White	Chipping	8	0.1	N/A
6470			Auditorium Stage	yes	W2	Concrete	Black	Chipping	15	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Auditorium Stage	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Stair stringer	Metal	Black	Chipping	6	0.2	N/A
6470			Auditorium Stage	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Black	Chipping	12	0.1	N/A
6470			Auditorium Stage	yes	W4	N/A	N/A	N/A	N/A	N/A	N/A	Stair stringer	Metal	Black	Chipping	6	0.2	N/A
6470			Auditorium Stage	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Black	Chipping	12	0.1	N/A
6470			Storage Room and Entrance Area to	no	W2	Concrete	Tan	Chipping	8	0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Control Room at Rear of Auditorium	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Window sill	Metal	Blue	Chipping	6	0.2	N/A
6470			Storage Room to Right of Control Room at	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Storage Room to Left of Stage	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Open Storage Area to Left of Stage outside	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Open Storage Area to Right of Stage	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Storage Room to Right of Stage	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Dressing A	no	NO ACCESS	No Access	No Access	No Access	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Dressing B	no	NO ACCESS	No Access	No Access	No Access	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Dressing B Restroom	no	NO ACCESS	No Access	No Access	No Access	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Dressing C Restroom	no	NO ACCESS	No Access	No Access	No Access	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Dressing C	no	NO ACCESS	No Access	No Access	No Access	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Dressing D	no	NO ACCESS	No Access	No Access	No Access	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Music Room	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Music Room Closet	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

			Lead Safe Certification															
			Name of Inspector: Charles Rhodes						Inspection Dates: 2/26/20 - 2/27/20									
			Inspection Company: Batta Environmental						ULCS#									
ULCS#	E	Space Type	On-Site Room Name	Student	Primary	Substrate	Color	Descriptio	Primary	XRF Reading	Primary	Additional Component	Substrate	Color	Description of	Additional	XRF Reading	Additional Component XRF
6470			Science Room	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	18	0.2	N/A
6470			Science Room Closet at Rear of Room	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	4	0.2	N/A
6470			Science Room Closet at Front of Room	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.2	N/A
6470			Classroom adjacent to Women's Restroom	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	4	0	N/A
6470			Women's Restroom adjacent to Nurse's	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	4	0.2	N/A
6470			Nurse's Office Storage Area across from	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	2	0	N/A
6470			Nurse's Office Restroom	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	1	0	N/A
6470			Office inside Nurse's Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	1	0	N/A
6470			Nurse's Office Exam Room	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	2	0.2	N/A
6470			Nurse's Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	7	0	N/A
6470			Men's Restroom by Cafeteria	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	4	0.2	N/A
6470			Custodial Closet adjacent to Men's	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Red	Chipping	6	-0.3	N/A
6470			Conference Room between Nurse's Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	6	0.1	N/A
6470			Main Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping	4	0.2	N/A
6470			Work Room/Copy Room/Office Supplies	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping	5	0	N/A
6470			Hallway inside Main Office to Principal's	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Administrative Assistant Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping	4	0.1	N/A
6470			Main Office Mechanical Room	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping	4	0.3	N/A
6470			Principal's Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping	2	0.1	N/A
6470			Principal's Office Restroom	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Counselor's Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping	6	0.2	N/A
6470			Telecommunication Equipment Room	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 101	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Classroom 101	yes	W1	Sheetrock	Yellow	Flaking	10	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 101	yes	W2	Sheetrock	Yellow	Flaking	5	-0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 101	yes	W4	Concrete	White	Flaking	5	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 101	yes	W4	Concrete	Yellow	Flaking	2	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 101 Small Restroom	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 101 Large Restroom	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Classroom 101 Large Restroom	yes	W1	Sheetrock	White	Flaking	10	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 101 Large Restroom	yes	W2	Sheetrock	White	Flaking	5	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 102	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 102	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	Negative
6470			Office 102A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Office 102A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	Negative
6470			Office 103A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Office 103A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 103	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 103	yes	W1	Sheetrock	White	Flaking	3	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 103	yes	W4	Sheetrock	White	Flaking	2	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 104	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 104	yes	W1	Sheetrock	White	Flaking	10	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 104	yes	W1	Sheetrock	Blue	Flaking	25	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 104	yes	W3	Concrete	Blue	Flaking	10	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 104	yes	W4	Concrete	Blue	Flaking	10	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 104	yes	W4	Sheetrock	Blue	Flaking	25	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 105	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 105	yes	W1	Sheetrock	Blue	Flaking	5	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 105	yes	W1	Sheetrock	White	Flaking	5	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 106	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 106	yes	W1	Sheetrock	White	Flaking	5	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 106	yes	W2	Sheetrock	Blue	Flaking	5	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 107	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 107	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 108	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue/WHITE	Flaking	10	0	Negative
6470			Classroom 108	yes	W4	Concrete	Blue	Flaking	5	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 109	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative



			Lead Safe Certification															
			Name of Inspector: Charles Rhodes							Inspection Dates: 2/26/20 - 2/27/20								
			Inspection Company: Batta Environmental						ULCS#									
ULCS#	E	Space Type	On-Site Room Name	Student	Primary	Substrate	Color	Descriptio	Primary	XRF Reading	Primary	Additional Component	Substrate	Color	Description of	Additional	XRF Reading	Additional Component XRF
6470			Classroom 109	yes	W4	Concrete	Blue	Flaking	10	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Girl's Restroom across from Classroom 108	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Girl's Restroom across from Classroom 108	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	Negative
6470			Girl's Restroom across from Classroom 108	yes	W4	Concrete	Blue	Flaking	5	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Girl's Restroom across from Classroom 108	yes	W4	Concrete	Tan	Flaking	5	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Girl's Restroom across from Classroom 108	yes	Ceiling	Concrete	Tan	Flaking	10	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Girl's Restroom across from Classroom 108	yes	Ceiling	N/A	N/A	N/A	N/A	N/A	N/A	DUCT	Metal	Tan	Flaking	10	0.1	Negative
6470			Custodial Closet across from Classroom	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Tan	Flaking	10	0	Negative
6470			Custodial Closet across from Classroom	no	W4	Concrete	White	Flaking	5	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Boy's Restroom across from Classroom 109	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Boy's Restroom across from Classroom 109	yes	Ceiling	Concrete	White	Flaking	10	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 110	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 110	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 111	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Grey	Flaking	10	0	Negative
6470			Classroom 112	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Classroom 112	yes	W1	Sheetrock	Blue	Flaking	15	-0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 112	yes	W2	Sheetrock	Blue	Flaking	5	0	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 112	yes	W4	Sheetrock	Blue	Flaking	10	-0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 113	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Classroom 114	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Classroom 114	yes	W1	Sheetrock	White	Flaking	2	-0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 114	yes	W4	Sheetrock	Blue	Flaking	5	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 114	yes	W4	N/A	N/A	N/A	N/A	N/A	N/A	COAT RACK	Wood	Blue	Flaking	20	0.1	Negative
6470			Elevator	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Elevator Mechanical Room adjacent to	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Girl's Restroom near Elevator	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Girl's Restroom near Elevator	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	5	0	Negative
6470			Girl's Restroom near Elevator	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Window frame	Metal	Blue	Flaking	20	0	Negative
6470			Girl's Restroom near Elevator	yes	W4	Concrete	White	Flaking	2	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Girl's Restroom near Elevator	yes	Ceiling	N/A	N/A	N/A	N/A	N/A	N/A	DUCT	Metal	White	Flaking	5	0.2	Negative
6470			Pipe Chase between Boy's and Girl's	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Boy's Restroom near Elevator	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Boy's Restroom near Elevator	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	5	0	Negative
6470			Boy's Restroom near Elevator	yes	Ceiling	Concrete	White	Flaking	10	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Custodial Closet across from Elevator	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Storage Room across from Classroom 114	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Storage Room across from Classroom 114	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	5	0	Negative
6470			Electrical Room by IMC	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Men's Restroom near Main Lobby	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0.1	Negative
6470			Men's Restroom near Main Lobby	yes	W4	N/A	N/A	N/A	N/A	N/A	N/A	Urinal Divider	Metal	Blue	Flaking	5	0.1	Negative
6470			Men's Restroom near Main Lobby Pipe	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	2	0.2	Negative
6470			Women's Restroom near Main Lobby	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0	Negative
6470			IMC	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	5	0	Negative
6470			IMC	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0	Negative
6470			IMC	yes	W2	Concrete	Blue	Flaking	2	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			IMC	yes	W2	Sheetrock	Green	Flaking	5	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			IMC	yes	Floor	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Grey	Flaking	40	0.1	Negative
6470			IMC 1 Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0.1	Negative
6470			IMC 2 Storage	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Copy Room	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Open Storage Area adjacent to Copy Room	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			IMC 4 Storage	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0.2	Negative
6470			IMC 5 Office	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0.2	Negative
6470			Hallway outside Classrooms K-3 to K-6	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Vestibule between Classroom K-1 and	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway across from Classroom K-4 to	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway to Gym	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

			Lead Safe Certification															
			Name of Inspector: Charles Rhodes						Inspection Dates: 2/26/20 - 2/27/20									
			Inspection Company: Batta Environmental						ULCS#									
ULCS#	E	Space Type	On-Site Room Name	Student	Primary	Substrate	Color	Descriptio	Primary	XRF Reading	Primary	Additional Component	Substrate	Color	Description of	Additional	XRF Reading	Additional Component XRF
6470			Stairwell from Cafeteria to Exterior Entrance	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway to Left of Stage to Exterior	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway to Right of Stage to Exterior	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Main Lobby	yes	W1	Plaster	Tan	Chipping	10	0.4	N/A	Columns	Concrete	Tan	Flaking	30	0.4	N/A
6470			Main Lobby	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping	22	0	N/A
6470			Main Lobby	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping	4	0	N/A
6470			Main Lobby	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	18	-0.2	N/A
6470			Main Lobby	yes	W3	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	32	0	N/A
6470			Hallway outside Nurse's Office	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway adjacent to Science Room to	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	10	0	N/A
6470			Hallway adjacent to Science Room to	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Columns	Concrete	Green	Chipping	30	0.1	N/A
6470			Hallway adjacent to Science Room to	yes	W4	Concrete	Green	Chipping	6	0.1	N/A	Columns	Concrete	Green	Chipping	35	0.1	N/A
6470			Main Entrance	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	8	0.2	N/A
6470			Hallway from Main Lobby to IMC	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classrooms 102-103	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Hallway outside Classrooms 102-103	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	N/A
6470			North Stairwell next to Classroom 103	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Grey	Chipping	40	0.2	N/A
6470			Hallway outside Classrooms 104-105	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	N/A
6470			Hallway outside Classrooms 104-105	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	20	0	N/A
6470			Hallway outside Classrooms 104-105	yes	W2	Plaster	White	Chipping	10	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classrooms 104-105	yes	W4	Plaster	White	Chipping	10	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classrooms 106-107	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Hallway outside Classrooms 106-107	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	N/A
6470			East Stairwell next to Classroom 107	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classrooms 108-109	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Hallway outside Classrooms 108-109	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	N/A
6470			Hallway outside Classrooms 110-111	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Hallway outside Classrooms 110-111	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	N/A
6470			South Stairwell next to Classroom 111	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Grey	Chipping	20	0.2	N/A
6470			Hallway outside Classrooms 112-113	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Hallway outside Classrooms 112-113	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	N/A
6470			Hallway outside Classrooms 112-113	yes	W2	Plaster	White	Chipping	10	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classrooms 112-113	yes	W4	Plaster	White	Chipping	10	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classroom 114	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			West Stairwell next to Classroom 114	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Grey	Chipping	10	0.2	N/A
6470			Boy's Restroom across from Classroom 216	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Girl's Restroom across from Classroom 201	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Girl's Restroom across from Classroom 201	yes	Ceiling	Concrete	White	Flaking	15	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Storage Room across from Classroom 201	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 201	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 202	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	5	0	Negative
6470			Classroom 202	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	5	0	Negative
6470			Auditorium Balcony	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 202A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 202A Mechanical Room	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 203	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 203	yes	W1	Sheetrock	White	Flaking	1	0	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 203	yes	W1	Sheetrock	Blue	Flaking	10	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 203	yes	W4	Sheetrock	Blue	Flaking	20	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 203 Closet	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 204	yes	W1	Sheetrock	Blue	Cracking	15	0.1	Negative	Door Frame	Metal	Blue	Chipping	10	0.1	Negative
6470			Classroom 204	yes	W1	N/A	N/A	None	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0.1	Negative
6470			Lounge/Copy Room 204A	yes	W1	Concrete	Blue	Cracking	40	0.2	N/A	Door Frame	Metal	Blue	Chipping	10	0.4	N/A
6470			Lounge/Copy Room 204A	yes	W2	Concrete	Blue	Cracking	20	0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Lounge/Copy Room 204A	yes	W3	Concrete	Blue	Cracking	40	0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Lounge/Copy Room 204A	yes	W4	Concrete	Blue	Cracking	20	-0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 205	yes	W1	Plaster	Blue	Chipping	5	0.1	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A

			Lead Safe Certification															
			Name of Inspector: Charles Rhodes						Inspection Dates: 2/26/20 - 2/27/20									
			Inspection Company: Batta Environmental						ULCS#									
ULCS#	E	Space Type	On-Site Room Name	Student	Primary	Substrate	Color	Descriptio	Primary	XRF Reading	Primary	Additional Component	Substrate	Color	Description of	Additional	XRF Reading	Additional Component XRF
6470			Classroom 205	yes	W3	Concrete	Blue	Cracking	5	-0.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Office 205A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	5	0.2	N/A
6470			Classroom 206	yes	W1	Plaster	Pink	Chipping	5	0	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A
6470			Classroom 206	yes	W2	Plaster	Pink	Chipping	1	0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 206	yes	W3	N/A	N/A	N/A	N/A	N/A	N/A	Radiator	Metal	Blue	Chipping	20	0	N/A
6470			Classroom 206 Closet	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 207	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	10	0	N/A
6470			Classroom 207	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.4	N/A
6470			Men's Restroom across from Classroom	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	5	0.1	N/A
6470			Men's Restroom across from Classroom	yes	W3	Concrete	White	Flaking	5	-0.1	N/A	Air Duct	Metal	N/A	Chipping	2	-0.1	N/A
6470			Mechanical Room behind Men's Restroom	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Boy's Restroom across from Classroom 208	yes	W1	Concrete	White	Chipping	10	0.3	N/A	Door Frame	Metal	Blue	Chipping	10	0.3	N/A
6470			Storage D	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Storage D Pipe Chase	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Girl's Restroom across from Classroom 209	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.4	N/A
6470			Girl's Restroom across from Classroom 209	yes	W2	Concrete	White	Chipping	5	-0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Girl's Restroom across from Classroom 209	yes	W3	Concrete	White	Chipping	10	0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 208	yes	W1	Concrete	Blue	Chipping	2	0.2	N/A	Door Frame	Metal	Blue	Chipping	10	0.2	N/A
6470			Classroom 208	yes	W3	Concrete	Blue	Chipping	5	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 209	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.3	N/A
6470			Classroom 209	yes	W3	Concrete	Green	Chipping	5	-0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Office 210A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	10	0.1	Negative
6470			Office 210A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	Negative
6470			Office 210A Mechanical Room	no	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 210	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	10	0.1	N/A
6470			Classroom 210	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A
6470			Classroom 210	yes	W4	Concrete	Blue	Chipping	5	0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 211	yes	W1	Concrete	Yellow	Flaking	10	0	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A
6470			Classroom 211	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	5	0.4	N/A
6470			Classroom 211	yes	W2	Concrete	Yellow	Flaking	10	0	N/A	Radiator	Metal	Blue	Chipping	10	0.1	N/A
6470			Classroom 211	yes	W3	N/A	N/A	N/A	N/A	N/A	N/A	Coat Rack	Wood	Yellow	Chipping	10	0.1	N/A
6470			Classroom 211	yes	W4	Concrete	Yellow	Flaking	20	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 211 Closet	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 212	yes	W1	Plaster	Blue	Flaking	5	-0.2	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Classroom 212	yes	W2	Plaster	Tan	Flaking	2	0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 212	yes	W3	Plaster	Tan	Flaking	5	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 212	yes	W4	Plaster	Blue	Flaking	2	-0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Office 212A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0.3	N/A
6470			Classroom 213	yes	W1	Plaster	Purple	Flaking	10	0.2	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Classroom 213	yes	W2	Plaster	Purple	Flaking	15	0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 213	yes	W4	Plaster	Purple	Flaking	10	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Office 213A	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Office 213A	yes	W3	Concrete	Yellow	Chipping	10	0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 214	yes	W1	Plaster	Purple	Flaking	5	0.1	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Classroom 214	yes	W2	Plaster	Purple	Flaking	5	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 214 Closet	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 215	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Classroom 215	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	N/A
6470			Classroom 215	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0.1	N/A
6470			Storage Room adjacent to Classroom 215	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0.1	Negative
6470			Storage Room adjacent to Classroom 215	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	10	0	Negative
6470			Storage Room adjacent to Classroom 215	no	Ceiling	Concrete	White	Flaking	5 SF	0.2	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Women's Restroom across from Classroom	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0	N/A
6470			Mechanical Room behind Women's	no	Ceiling	Concrete	White	Chipping	5	0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 216	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 216 Restroom	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	Negative
6470			Classroom 217A	yes	W1	Concrete	Blue	Flaking	70	0.1	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A

			Lead Safe Certification															
			Name of Inspector: Charles Rhodes					Inspection Dates: 2/26/20 - 2/27/20										
			Inspection Company: Batta Environmental					ULCS#										
ULCS#	E	Space Type	On-Site Room Name	Student	Primary	Substrate	Color	Descriptio	Primary	XRF Reading	Primary	Additional Component	Substrate	Color	Description of	Additional	XRF Reading	Additional Component XRF
6470			Classroom 217A	yes	W3	Plaster	Blue	Chipping	50	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 217A	yes	W4	Plaster	Blue	Chipping	50	-0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 217B	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Coatrack	Wood	Green	Chipping	10	-0.2	N/A
6470			Classroom 217B	yes	W2	Plaster	Green	Flaking	10	0.1	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A
6470			Classroom 217B	yes	W3	Plaster	Green	Flaking	20	0.1	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A
6470			Classroom 217B	yes	W4	Concrete	Tan	Cracking	10	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 217B	yes	Ceiling	Plaster	Blue	Effloresce	10	0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Classroom 217C	yes	W1	Concrete	Blue	Flaking	70	0.2	N/A	Coatrack	Wood	Blue	Chipping	20	-0.2	N/A
6470			Classroom 217C	yes	W3	Plaster	Blue	Chipping	40	-0.1	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A
6470			Hallway outside Classrooms 216-201	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0	Negative
6470			Hallway outside Classrooms 216-201	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	20	0	Negative
6470			Hallway outside Classrooms 216-201	yes	W1	Concrete	White	Flaking	5	0.1	Negative	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classrooms 202-203	yes	W1	Concrete	White	Cracking	10	-0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classrooms 202-203	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	10	0	N/A
6470			Hallway across from North Stairwell to	yes	W2	Concrete	White	Cracking	40	-0.1	N/A	Hand rails	Metal	Grey	Chipping	10	0	N/A
6470			Hallway across from North Stairwell to	yes	W3	Concrete	White	Cracking	10	-0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway across from North Stairwell to	yes	W4	Concrete	White	Cracking	40	-0.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			North Stairwell next to Classroom 203	yes	Floor	N/A	N/A	None	N/A	N/A	N/A	Hand rails	Metal	Grey	Chipping	40	0.2	Negative
6470			Hallway outside Classrooms 204-205	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	10	0.2	N/A
6470			Hallway outside Classrooms 206-207	yes	W1	Concrete	White	Cracking	40	0.2	N/A	Door	Metal	Blue	Chipping	10	0.2	N/A
6470			Hallway across from East Stairwell to	yes	W2	Concrete	White	Cracking	40	0.2	N/A	Door	Metal	Blue	Chipping	10	0.2	N/A
6470			East Stairwell next to Classroom 207	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Grey	Chipping	40	0.1	N/A
6470			Hallway outside Classrooms 208-209	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	20	0	N/A
6470			Hallway outside Classrooms 208-209	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Hallway outside Classrooms 208-209	yes	W4	Concrete	White	Chipping	2	-0.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classrooms 210-211	yes	W1	Concrete	White	Flaking	10	-0.2	N/A	Door	Metal	Blue	Flaking	20	0	N/A
6470			Hallway outside Classrooms 210-211	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0.1	N/A
6470			Hallway across from South Stairwell to	yes	NO DAMAGE	N/A	N/A	None	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			South Stairwell next to Classroom 211	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Grey	Chipping	40	-0.1	N/A
6470			Hallway outside Classrooms 212-213	yes	W1	Plaster	White	Cracking	8	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6470			Hallway outside Classrooms 212-213	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Flaking	20	0.1	N/A
6470			Hallway outside Classrooms 212-213	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Hallway outside Classrooms 214-215	yes	W1	Concrete	White	Chipping	N/A	N/A	N/A	Door	Metal	Blue	Flaking	20	0.1	N/A
6470			Hallway outside Classrooms 214-215	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Flaking	10	0	N/A
6470			Hallway across from West Stairwell to	yes	Floor	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Grey	Chipping	10	0	N/A
6470			West Stairwell next to Classroom 214	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Hand rails	Metal	Grey	Chipping	40	-0.1	N/A



[illegible]



[illegible]

Task ID	ULCS#	E i e m e n t	Bldg ID	F i o o r	Space # (on Floor Plan)	Space Type	On Site Room Name	Student/Teacher Occupied	Primary Component	Substrate Material	Color	Description of Paint and Plaster Damage Primary Component	Primary Component Quantity (sf)	XRF Reading (mg/cm2)	Primary Component XRF (positive/negative)	Additional Component	Substrate Material	Color	Description of Paint and Plaster Damage Additional Component	Additional Component Quantity (sf)	XRF Reading (mg/cm2)	Additional Component XRF (positive/negative)	Date Mold DDC Issued	Date Asbestos DDC Issued	Miscellaneous Items (e.g. misapplied ceiling tiles, steam leaks, missing lens covers, buckled floors, etc.)	Date Notified FAC	Pre-Cleaning Completed (date)	Contents Moved (date)	Work Area Prepped (date)	Surfaces Sampled (date)	Contents Back in Place (date)	Final Inspection Approval and Photos (date)	Square Footage of Work Area	Number of Required RRP Wipes	Number of Colormetric Wipes Used to Pass	Final Colormetric for AAS Analysis (yes/no)	AAS Analysis Results	
1	6470	1	B821	3		Primary	Electrical Room	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Blue	Chipping	5	0	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
2	6470	1	B821	3		Primary	Boiler Room	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Grey	Chipping	5	0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
3	6470	1	B821	3		Stairs	Building Engineer's Office	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Tan	Chipping	10	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
4	6470	1	B821	3		Stairs	Building Engineer's Office	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Window frame	Metal	Tan	Chipping	5	0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
5	6470	1	B821	3		Stairs	Building Engineer's Office	no	W3	Plaster	Tan	Chipping	10	0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
6	6470	1	B821	3		Stairs	Building Engineer's Office Restroom	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Pipe	N/A	Tan	Chipping	20	-0.4	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
7	6470	1	B821	3		Primary	Staff Locker Room	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door	Metal	Brown	Chipping	5	0	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
8	6470	1	B821	3		Primary	Staff Locker Room	no	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	5	0	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
9	6470	1	B821	3		Primary	Staff Locker Room Restroom	no	NO DAMAGE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
10	6470	1	B821	3		Primary	Stairwell from 1st Floor to Boiler Room	no	NO DAMAGE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
11	6470	1	B821	3		Primary	Classroom K-1	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	8	-0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP					Yes	<5ug	
12	6470	1	B821	3		Storage	Classroom K-1	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Blue	Chipping	6	-0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
13	6470	1	B821	3		Storage	Classroom K-1	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Blue	Chipping	5	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
14	6470	1	B821	3		Storage	Classroom K-1 Restroom	yes	Floor	Concrete	Grey	Chipping	10	0.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
15	6470	1	B821	3		Storage	Classroom K-1 Closet	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Tan	Chipping	6	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
16	6470	1	B821	3		Storage	Vestibule between Classroom K-1 and Storage	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	5	0	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
17	6470	1	B821	3		Storage	Vestibule between Classroom K-1 and Storage	yes	W3	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	2	0	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
18	6470	1	B821	3		Primary	Closet between Classrooms K-1 & K-2	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Tan	Chipping	10	0.3	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
19	6470	1	B821	3		Primary	Classroom K-2	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	9	0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
20	6470	1	B821	3		Primary	Classroom K-2	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Blue	Chipping	10	0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
21	6470	1	B821	3		Primary	Classroom K-2 Closet	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Blue	Chipping	6	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
22	6470	1	B821	3		Primary	Classroom K-2 Restroom	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	2	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
23	6470	1	B821	3		Primary	Classroom K-2 Closet	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Tan	Chipping	6	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
24	6470	1	B821	3		Stairs	Vestibule between Classroom K-2 and Stairs	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.4	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
25	6470	1	B821	3		Stairs	Vestibule between Classroom K-2 and Stairs	yes	W3	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	3	0	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
26	6470	1	B821	3		Primary	Classroom K-3	yes	W1	Concrete	Blue	Chipping	8	0.1	N/A	Door Frame	Metal	Brown	Chipping	8	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
27	6470	1	B821	3		Primary	Classroom K-3	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Blue	Chipping	27	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP						Yes	5.9ug
28	6470	1	B821	3		Primary	Classroom K-3	yes	W3	Concrete	N/A	Cracking	11	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
29	6470	1	B821	3		Primary	Classroom K-3	yes	W4	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Blue	Chipping	12	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
30	6470	1	B821	3		Primary	Classroom K-3 Closet	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
31	6470	1	B821	3		Primary	Classroom K-3	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	1	0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
32	6470	1	B821	3		Primary	Vestibule between Classroom K-3 and Stairs	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.4	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
33	6470	1	B821	3		Administrative	Vestibule between Classroom K-3 and Stairs	yes	W3	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	10	0	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
34	6470	1	B821	3		Administrative	Closet between Classrooms K-3 & K-4	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	5	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
35	6470	1	B821	3		Primary	Classroom K-4	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	10	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
36	6470	1	B821	3		Primary	Classroom K-4	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Blue	Chipping	14	0.3	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
37	6470	1	B821	3		Primary	Classroom K-4	yes	W2	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Blue	Chipping	8	0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
38	6470	1	B821	3		Administrative	Classroom K-4 Restroom	yes	N/A	Floor	Concrete	N/A	Chipping	10	0.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
39	6470	1	B821	3		Circulation	Classroom K-4 Restroom	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	4	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
40	6470	1	B821	2		Primary	Classroom K-4 Closet	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	4	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
41	6470	1	B821	2		Stairs	Vestibule between Classroom K-4 and Stairs	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Blue	Chipping	10	0.3	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
42	6470	1	B821	2		Stairs	Vestibule between Classroom K-4 and Stairs	yes	W3	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Brown	Chipping	10	0.2	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
43	6470	1	B821	2		Primary	Classroom K-5	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Black	Chipping	2	0	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP						Yes	6.6ug
44	6470	1	B821	2		Primary	Classroom K-5	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Green	Chipping	20	0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
45	6470	1	B821	2		Primary	Classroom K-5	yes	W3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
46	6470	1	B821	2		Primary	Classroom K-5	yes	W4	N/A	N/A	N/A	N/A	N/A	N/A	Built-in cabinet	Wood	Green	Chipping	8	0	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
47	6470	1	B821	2		Primary	Classroom K-5 Restroom	yes	Floor	Concrete	N/A	Chipping	16	0.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
48	6470	1	B821	2		Primary	Classroom K-5 Closet	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping	11	0.1	N/A			NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP	NO RRP							
49	6470	1	B821	2		Primary	Vestibule between Classroom K-5 and Stairs	yes	W1	N/A	N/A	N/A	N/A	N/A	N/A	Door Frame	Metal	Green	Chipping</																			

[illegible]

[illegible]

Phila SD - J.B. Kelly



BATTA Laboratories, LLC

3 Lead Wipes

## BL Sample Custody Transmittal Sheet

### Project Information

BL Project # : <u>L165820</u>	BEA Project # : <u>543520F</u>
Range of BATTA Lab Sample # : <u>20081703.</u>	
Checked for Special Instructions (see CoC): <u>IAA</u>	Initial if Checked

Date of Preliminary Results Requested By: 8/17/20 12:35

Date of Certificates Requested By: \_\_\_\_\_

Date & Lab Name for Outsourcing Sample(s): \_\_\_\_\_

### Transmittal Information

Quality Checked	Description of Activity	Date	Time	Initials
<input checked="" type="checkbox"/>	Sample Log-in by:	8/17/20	11:20	IAA
<input checked="" type="checkbox"/>	Sample Prep by:	8/17/20	830	SA
<input checked="" type="checkbox"/>	Sample Analysis Completed by:	8/17/20	1400	SA
<input checked="" type="checkbox"/>	Report/Data Entry Completed by:	8/17/20	1401	SA
<input checked="" type="checkbox"/>	Report Scanned & Delivered by:	8/17/20	1402	SA

Check a "✓" in the box to the right when you have quality-checked the package prior to handing off to the next station.

Results given:

☒ email

check those that apply

☐ verbals

Details:

Write details such as method of contact (email, verbal, etc.) and the person contacted

8/17/20  
Date

1405  
Time

QC and Signatory of Final Report

Date

Time

Initials

RIO

8/17/20

1405

RR

Dedicated to a Cleaner  
Environment Since 1982




NY ELAP# 11993  
PCM, PLM, TEM & LEAD



**BATTA LABORATORIES, LLC**  
Delaware Industrial Park, 6 Garfield Way  
Newark, DE 19713-5817  
Tel. (302)737-3376 Fax (302)-737-5764

Newark, DE - Columbia, MD -  
Philadelphia, PA

Web: <http://www.battaenv.com>  
E-mail: [battaenv@battaenv.com](mailto:battaenv@battaenv.com)



EPA Lab ID #DE004

**NVLAP**

Lab Code: 101032-0

## REPORT OF ANALYSIS

<b>Report#:</b>	RP20081704	<b>Date Sampled:</b>	08/14/2020
<b>Project Number:</b>	20081703	<b>Sampled By:</b>	E. Drake
<b>Project Name:</b>	Batta Environmental Associates	<b>Date Received:</b>	08/17/2020
<b>Project Location:</b>	543520F J.B. Kelly	<b>Date Analyzed:</b>	08/17/2020
<b>Analyte Requested:</b>	Lead	<b>Date Report Issued:</b>	08/17/2020
<b>Method</b>	Test Method: NIOSH 9100 / NIOSH 7082		
<b>Matrix:</b>	Wipe		

Lab Sample #	Client Sample ID	Sample Description	Sample Location	Sampled Area (ft <sup>2</sup> )	µg / sample	µg/ft <sup>2</sup>	Reporting Limit (µg/sample)
20081703.01	K1-01	Room K1	n/a	1.00	<5	<5	5
20081703.02	K3-02	Room K3	n/a	1.00	5.90	5.90	5
20081703.03	K3-03	Room K5	n/a	1.00	6.60	6.60	5

Note: 1. Blank values were not subtracted from reported sample values; 2. Quality control results in this report are acceptable; 3. Results relate only to the items tested; 4. Batta Laboratories, Inc. is not responsible for sample collection, nor interpretations made by others; and 5. This report does not constitute endorsement by AIHA LAP, LLC., NVLAP and/or any other U.S. governmental agencies; 6. Lab results/calculations are reported in 2 significant figures. Clients data/measurements are reported as they were submitted; 7. EPA guidelines for clearance lead wipes have been set at the following levels: Floors not to exceed 10 ug/sq ft, window sills not to exceed 100 ug/sq ft, and window troughs not to exceed 400 ug/sq ft. Samples received in acceptable condition unless otherwise noted. 8. Clearance guidelines for OLCCH, LBPHC and LHRD Grantees are set at the following levels: Floors not to exceed 10ug/sq ft, window sills not to exceed 100ug/sq ft, window troughs not to exceed 100ug/sq ft and porch floors not to exceed 40ug/sq ft. Samples received in acceptable condition unless otherwise noted. 9. This report must not be reproduced without the written approval of BATTA Laboratories.

Batta Lab strives on customer feedback to improve the quality of our services. Please e-mail your feedback to [feedback@battaenv.com](mailto:feedback@battaenv.com).

**Analyst:** Samusi Adediran

**End of Report**

**QA/QC BY:** [Signature]  
N.C. Batta/R Shumate (QA/QC Officer)





**EHS TRAINING INSTITUTE, INC.**  
A Division of BATTI, Inc.

# **Certificate of Completion**

## **1-Day Initial**

### **Delaware Dust Wipe Technician**

### **EPA Lead Dust Sampling Technician**

**Awarded To:**  
English

**Emlyn Drake**

306 Buttonwood Road Landenberg, PA 19350

Who has successfully completed the attendance, hands-on, and testing requirements for this course.

**EHS TRAINING INSTITUTE, INC.**

A Division of BATTI, Inc.

Delaware Industrial Park • 6 Garfield Way  
Newark, DE 19713-5817  
(302) 737-3376 • Fax (302) 737-5764



**Todd K. Zeisloft, Training Manager**

**Todd K. Zeisloft, Principal Instructor**

Course Date: **May 1, 2019** Exam Date: **May 1, 2019**  
Certification Number : **TP-DWT-I-18-0027-18-00001**  
DE Exp May 1, 2021 EPA Exp May 1, 2024



**EHS TRAINING INSTITUTE, INC.**  
A Division of BATTI, Inc.

# Certificate of Completion

## 1-Day Initial Delaware Lead Renovator (RRP)

English

**Awarded To:**  
**Emlyn Drake**  
306 Buttonwood Rd Landenberg, PA 19350

Who has successfully completed the attendance and testing requirements for this course.

**EHS TRAINING INSTITUTE, INC.**  
A Division of BATTI, Inc.  
Delaware Industrial Park • 6 Garfield Way  
Newark, DE 19713-5817  
(302) 737-3376 • Fax (302) 737-5764



Course Date: **March 21, 2019** Exam Date: **March 21, 2019**  
Certification Number : **TP-RRP-I-18-0013R-00032**  
DE Exp **March 21, 2021** EPA Exp **March 21, 2024**



**Todd K. Zeisloft, Training Manager**



**Todd K. Zeisloft, Principal Instructor**