



Classroom ID / Area ID Number	Classroom / Area Type supplied	Actual Outside Air CFM (OA)	Occupancy (OA CFM / 15)	
Decatur Main Building				
K-1	Classroom	0	0.00	
K-2	Classroom	0	0.00	
100	Classroom	0	0.00	
101	Classroom	0	0.00	
102	Classroom	0	0.00	
103	Classroom	0	0.00	
104	Classroom	0	0.00	
105	Classroom	0	0.00	
106	Classroom	0	0.00	
107	Classroom	0	0.00	
108	Classroom	0	0.00	
109	Classroom	0	0.00	
110	Classroom	0	0.00	
Office	Classroom	0	0.00	
Basement	Basement	0	0.00	
Basement	Basement	0	0.00	
Basement	Basement	0	0.00	
Gym	Gym	186	12.40	
Gym	Gym	348	23.20	
Auditorium	Auditorium	675	45.00	
First Floor	First Floor	0	0.00	
Second Floor	Second Floor	0	0.00	
Third Floor	Third Floor	0	0.00	
Basement	Basement	0	0.00	
Annex Building	Annex Building	0	0.00	
White Building	White Building	0	0.00	
Decatur Annex				
A-1	Classroom	47	3.13	
A-2	Classroom	153	10.20	
A-3	Classroom	216	14.40	



School: Decatur Vendor: EMCORE

Certified Air Balancing Report

A-4	Classroom	153	10.20
A-5	Classroom	213	14.20
A-6	Classroom	163	10.87
A-7	Classroom	166	11.07
A-8	Classroom	153	10.20
A-9	Classroom	95	6.33
A-10	Classroom	130	8.67
	Decatur White Bu	ilding	
Rm. 2	Classroom	241	16.07
Rm. 3	Classroom	193	12.87
Rm. 4	Classroom	0	0.00
Rm. 1	Classroom	315	21.00
		2100	140.00