



Vendor: Devine Brothers Certified Air Balancing Report

Classroom ID / Area ID Number	Classroom / Area Type supplied	Actual Outside Air CFM (OA)	Occupancy (OA CFM / 15)
	Auditorium	1,451.0	96.73
	Gym	1,279.0	85.27
101A	Classroom	0.0	0.00
102	Classroom	57.0	3.80
103	Classroom	0.0	0.00
105	Classroom	40.0	2.67
106	Classroom	51.0	3.40
107	Classroom	0.0	0.00
108	Classroom	164.0	10.93
109	Classroom	0.0	0.00
110A	Classroom	0.0	0.00
209	Classroom	0.0	0.00
210	Classroom	236.0	15.73
211	Classroom	89.0	5.93
212	Classroom	62.0	4.13
213	Classroom	150.0	10.00
214	Classroom	155.0	10.33
Main Office	Admin	0.0	0.00
	Library	0.0	0.00
	Library	129.0	8.60
217	Classroom	167.0	11.13
218	Classroom	79.0	5.27
219	Classroom	0.0	0.00
318	Classroom	0.0	0.00
319	Classroom	0.0	0.00
320	Classroom	0.0	0.00
321	Classroom	64.0	4.27
322	Classroom	58.0	3.87
323	Classroom	0.0	0.00
324	Classroom	158.0	10.53
325	Classroom	0.0	0.00
326	Classroom	87.0	5.80
327	Classroom	67.0	4.47
327A	Classroom	0.0	0.00