



Vendor: Devine Brothers Certified Air Balancing Report

Classroom ID / Area ID Number	Classroom / Area Type supplied	Actual Outside Air CFM (OA)	Occupancy (OA CFM / 15)
1	Classroom	380.0	25.33
2	Classroom	321.0	21.40
3	Classroom	387.0	25.80
4	Classroom	304.0	20.27
5	Classroom	313.0	20.87
6	Classroom	268.0	17.87
7	Classroom	351.0	23.40
8	Classroom	334.0	22.27
9	Classroom	235.0	15.67
10	Classroom	375.0	25.00
11	Classroom	242.0	16.13
12	Classroom	234.0	15.60
13	Classroom	227.0	15.13
Main Entrance	Entrance	68.0	4.53
103A	Classroom	290.0	19.33
103B	Classroom	311.0	20.73
104A	Classroom	328.0	21.87
104B	Classroom	368.0	24.53
105A	Classroom	292.0	19.47
105B	Classroom	372.0	24.80
106A	Classroom	94.0	6.27
106B	Classroom	458.0	30.53
201	Classroom	418.0	27.87
202	Classroom	292.0	19.47
203	Classroom	136.0	9.07
204	Classroom	259.0	17.27
205	Classroom	377.0	25.13
206	Classroom	338.0	22.53
207	Classroom	238.0	15.87
208	Classroom	121.0	8.07
209	Classroom	244.0	16.27
210	Classroom	240.0	16.00
211	Classroom	263.0	17.53





Vendor: Devine Brothers Certified Air Balancing Report

212	Classroom	332.0	22.13
213A	Classroom	200.0	13.33
213B	Classroom	299.0	19.93
Admin	Main Office	56.0	3.73
Admin	Office	28.0	1.87
Counselor	Office	107.0	7.13
Nurse	Office	71.0	4.73
Music 117	Office	0.0	0.00
Computer Lab A	Classroom	96.0	6.40
Computer Lab B	Classroom	72.0	4.80
116	Studio	0.0	0.00
IMC-A	Classroom	874.0	58.27
IMC-B	Classroom	90.0	6.00
IMC-C	Classroom	0.0	0.00
IMC-D	Classroom	196.0	13.07
IMC-E	Classroom	0.0	0.00
IMC-F	Classroom	38.0	2.53
GYM	Gym	0.0	0.00
	Gym Locker Rooms	335.0	22.33
	AUDITORIUM	1,185.0	79.00
	Multi-Purpose	2,016.0	134.40